ELECTRICAL ONE LINE DIAGRAM FOR RUNWAY 15 WIND CONE

ELECTRICAL NOTES

- 1. ALL ELECTRICAL EQUIPMENT SHALL BE INSTALLED IN CONFORMANCE WITH NFPA70 (MOST CURRENT ISSUE IN FORCE), THE RESPECTIVE EQUIPMENT MANUFACTURER'S DIRECTIONS AND ALL OTHER APPLICABLE LOCAL CODES, LAWS, ORDINANCES, AND REQUIREMENTS IN FORCE. ANY INSTALLATIONS WHICH VOID THE U.L. LISTING, ETL LISTING, (OR OTHER THIRD PARTY LISTING) AND/OR THE MANUFACTURER'S WARRANTY OF A DEVICE SHALL NOT BE PERMITTED.
- CONTRACTOR SHALL COORDINATE ANY POWER OUTAGES TO EXISTING EQUIPMENT WITH THE AIRPORT MANAGER, AND THE RESIDENT ENGINEER.
- 3. ALL EQUIPMENT NOT LABELED AS EXISTING IS NEW.
- PROVIDE NEMA 4 HUBS FOR ALL CONDUIT ENTRIES INTO NEMA 4 RATED ENCLOSURES.
- 5. ALL CONDUCTORS/WIRING SHALL BE COPPER.
- 6. WIND CONES SHALL BE PAID FOR UNDER AR107408.
- 7. BOOST TRANSFORMER FOR WIND CONE WITH A LOAD OF APPROXIMATELY 3.5 AMPS SHALL BE 250 VA, 120 VAC, TO 132 VAC UNIT, SQUARE D CAT. NO. 250S43B OR APPROVED EQUAL. BOOST TRANSFORMER FOR A WIND CONE WITH A LOAD OF APPROXIMATELY 7 AMPS SHALL BE 250 VA, 120 VAC, TO 144 VAC UNIT, SQUARE D CAT. NO. 250S43B OR APPROVED EQUAL. INTERFACE & CONNECT BOOST TRANSFORMER TO EXISTING CONTROL PANEL.
- LIFMC DENOTES LIQUID TIGHT FLEXIBLE METAL CONDUIT. LIQUID TIGHT FLEXIBLE METAL CONDUIT AND ASSOCIATED FITTINGS SHALL BE U.L. LISTED TO MEET THE REQUIREMENTS OF NEC 350.6., SUITABLE FOR GROUNDING AND SUNLIGHT RESISTANT. LIQUID TIGHT FLEXIBLE METAL CONDUIT THAT IS USED FOR FLEXIBILITY (INCLUDING CONNECTIONS TO TRANSFORMERS) SHALL REQUIRE AN EXTERNAL BONDING JUMPER OR INTERNAL EQUIPMENT GROUNDING CONDUCTOR PER NEC 350.60. DO NOT INSTALL LIQUID TIGHT FLEXIBLE METAL CONDUIT THAT IS NOT UL

MV054

KA HANSON

ELECTRICAL ONE LINE DIAGRAM FOR WIND CON

19 19 of 29 sheets

WORK SHOWN ON THIS SHEET IS FOR BASE BID

144 VAC OUPUT

120 VAC TO 144 VAC BOOST TRANSFORMER

CONFIRM WIRING WITH RESPECTIVE

CONNECTION DIAGRAM FOR SQUARE D CAT. NO. 250SV43B TRANSFORMER

TRANSFORMER MER.